



Water & Sewer Commission

CITY OF FREEPORT,

230 WEST STEPHENSON STREET, FREEPORT, ILLINOIS 61032

TELEPHONE: 815 233 – 0111

City-wide water meter replacement and
Advanced metering infrastructure (AMI) fixed network program

Addendum No. 3 3 August 2011

Clarification from the City of Freeport Regarding Use of Licensed Frequency 02646 Section 5.1 Meter Interface Unit

Reference the attached letter from the City of Freeport Water & Sewer Commission dated July 28, 2011.

Reminder to all Prospective Bidders

The City is seeking a TURN-KEY operation as clearly stated in paragraph one in Section 02646 Water Meter and Appurtenances, Part 1- General, 1.0 Project Scope. Each bidder is reminded they shall be held to this in the bid form by indicating Yes Or No to being able to meet the Specification, this shall be used in the determination as to where or not a bidder is responsive.

Modification to 02646, Part 1 (1.4)

The following language shall be removed:

“The bidder is responsible for verification of all telecommunications resources intended to be used in the back haul of data. Bidder is responsible for outlining quantity (if any) private or public class IP addresses that will be used for all devices and recommended VLAN configuration if appropriate.”

Language shall now read:

Bidder shall be responsible for establishing a central collector/host site at the City of Freeport’s City Hall. The bidder shall be responsible for backhauling from the remote data collectors to the central collector/host site by means of a regulated/protected method. The most appropriate method shall be determined upon completion of the propagation study.

Modification to 02646, Section 6.2 Delivery and Installation (E) (8)

The following language shall be removed:

“If the meter to be replaced has a strainer, the Bidder shall be responsible for replacing the strainer along with the meter, unless conditions prevent such replacement. Meters currently without strainers shall be supplied with strainers unless the meter location does not allow installation of a strainer without modification of plumbing/piping. Bidder shall otherwise be responsible for repairing or cleaning the strainer to ensure that is in good working order and will not adversely affect meter performance”

Language shall now read:

Meters currently with strainers shall be replaced by the successful Bidder for meter sizes 3, 4, & 6 inch. Should the proposed strainer not fit the location of the existing strainer, the existing strainer shall be cleaned and repaired by the Bidder such that it will not adversely impact meter performance, if this is not possible the Bidder shall bring the issue to attention of the City's Project Liaison. Three, four, and six inch meters currently without strainers shall be supplied with strainers unless the meter location does not allow installation of a strainer without modification of plumbing/piping. Any plumbing/piping modifications shall not be performed without prior approval from the City's Project Liaison.

All Addenda is available on the City of Freeport's website:
www.cityoffreeport.org/departments/water_sewer.htm

End Addendum No. 3